



NORITZ
 11160 Grace Avenue
 Fountain Valley, California 92708
 866-7NORITZ (866-766-7489)
 www.noritz.com

MODEL	EQUIPMENT LIST		
NC199-DVC	Item	Part Number	Qty
APPLICATION Commercial Recirculation Multi-Unit System Controller	Noritz DVC Model Tankless Water Heater	NC199-DVC	3-6
	System Controller	SC-201-6M-EXT-DVC	1
DRAWING NUMBER	Isolator Kit	IK-WV-7	3-6
	Pipe Cover	PC-5S	3-6
DRAWING DATE October 13, 2009	Expansion Tank	Field Supplied	1
	Pump	Field Supplied	1
	Aquastat	Field Supplied	1
	Globe Valve	Field Supplied	1
	Check Valve	Field Supplied	2

Note: This diagram is for reference only. Installation must comply with State and Local Code, all gas and water pipe must be sized correctly to specific length, according to accepted engineering methods or the UPC Code for Noritz Water Heaters to operate correctly.

	Shut-off Ball Valve		Aquastat (Honeywell Model #L6006A or L6006C)
	Check Valve		Pump
	Union		Mixing Valve
	Pressure Relief Valve (Watts 174A, Zurn P3000BR, Cash Acme F-82)		Thermal Expansion Tank