



NORITZ
 11160 Grace Avenue
 Fountain Valley, California 92708
 866-7NORITZ (866-766-7489)
 www.noritz.com

MODEL	NC199-DVC
APPLICATION	Commercial Recirculation Multi-Unit System Controller Storage Tank
DRAWING NUMBER	
DRAWING DATE	October 13, 2009

EQUIPMENT LIST		
Item	Part Number	Qty
Noritz DVC Model Tankless Water Heater	NC199-DVC	2-6
System Controller	SC-201-6M-EXT-DVC	1
Isolator Kit	IK-WV-7	2-6
Pipe Cover	PC-SS	2-6
Storage Tank	Field Supplied	1
Thermostat	Field Supplied	1
Expansion Tank	Field Supplied	1
Pump	Field Supplied	1
Aquastat	Field Supplied	1
Globe Valve	Field Supplied	1
Check Valve	Field Supplied	2

Note: This diagram is for reference only. Installation must comply with State and Local Code, all gas and water pipe must be sized correctly to specific length, according to accepted engineering methods or the UPC Code for Noritz Water Heaters to operate correctly.

	Shut-off Ball Valve		Aquastat (Honeywell Model #L6006A or L6006C)
	Check Valve		Pump
	Union		Mixing Valve
	Pressure Relief Valve (Watts 174A, Zurn P3000BR, Cash Acme F-82)		Thermal Expansion Tank