



**NORITZ**  
 11160 Grace Avenue  
 Fountain Valley, California 92708  
 866-7NORITZ (866-766-7489)  
 www.noritz.com

MODEL	EQUIPMENT LIST		
	Item	Part Number	Qty
APPLICATION Commercial Recirculation Multi-Unit System Controller	Noritz SV Model Tankless Water Heater	NC____-SV(-ASME)	3+
	Remote Controller	RC-7649M	1
	Remote Controller Cord	RC-CORD10	1
	System Controller	SC-201-12(24)M	1
	Isolator Kit	IK-WV-___	3+
	Vent Cap (Outdoor Use Only)	VC-____	3+
	Pipe Cover	PC-__S	3+
	Expansion Tank	Field Supplied	1
	Pump	Field Supplied	1
	Aquastat	Field Supplied	1
DRAWING NUMBER	Globe Valve	Field Supplied	1
	Check Valve	Field Supplied	2
DRAWING DATE	October 13, 2009		

*Note: This diagram is for reference only. Installation must comply with State and Local Code, all gas and water pipe must be sized correctly to specific length, according to accepted engineering methods or the UPC Code for Noritz Water Heaters to operate correctly.*

	Shut-off Ball Valve		Aquastat (Honeywell Model #L6006A or L6006C)
	Check Valve		Pump
	Union		Mixing Valve
	Pressure Relief Valve (Watts 174A, Zurn P3000BR, Cash Acme F-82)		Thermal Expansion Tank