



APPLICATION:

DRAWING NUMBER:

DRAWING DATE:

Hydronic Heating

Domestic Hot Water

Recirculation Loop

(6b1)N531S

September 22, 2008

11160 Grace Avenue Fountain Valley, California 92708 866-7NORITZ (866-766-7489) www.noritz.com

MODEL: **Noritz Accessories** N-0531S

RC-7649M (Remote Controller, Optional with N-0531S/N-0631S)



RC-CORD10 (10' Remote Controller Cord, optional in 26')



VC-3 (Outdoor Vent Cap, place on top of unit)

Note: This diagram is for reference only. Installation must comply with State and Local Code, all gas and water pipe must be sized correctly to specific length, according to accepted engineering methods or the UPC Code for Noritz Water Heaters to operate correctly.





Aquastat (Honeywell Model #L6006A or L6006C)



Pump

REVISIONS

1. Noritz recommends the use of Isolation Kit (IK-WV-4) with

DATE

APPRVD.

DESCRIPTION

REV.

Notes:



Mixing Valve



Pressure Relief Valve (Watts 3L, Zurn P1000A, Cash Acme FWL-2)



Thermal Expansion Tank