

RC-7649M (Remote Controller)

RC-CORD10 (10' Remote

Controller Cord, optional in 26')

VC-4-1 (Outdoor Vent Cap,

place on top of unit)

SC-201-6M (System Controller,

for 2 or more unit Multi-System)

APPLICATION:

DRAWING NUMBER:

DRAWING DATE:

NORITZ

11160 Grace Avenue

Fountain Valley, California 92708

866-7NORITZ (866-766-7489)

www.noritz.com

Hydronic Heating

2-6 Unit Multi-System

Domestic Hot Water

Recirculation

Primary Loop

(6b2-6)N931M

September 22, 2008

REVISIONS

1. Noritz recommends the use of Isolation Kit (IK-WV-5) with installation. These kits include an integrated shut-off and service

APPRVD.

DATE

Aquastat (Honeywell Model

Thermal Expansion Tank

#L6006A or L6006C)

Pump

Mixing Valve

DESCRIPTION

valve with unions and a pressure relief valve.

REV.

Notes:

all gas and water pipe must be sized correctly to specific length, according to accepted

engineering methods or the UPC Code for Noritz Water Heaters to operate correctly.

Shut-off Ball Valve

Pressure Relief Valve (Watts 174A,

Zurn P3000BR, Cash Acme F-82)

Check Valve

Union